

[illegible]

EAST ELEVATION

NOTES

RAINWATER DOWNPIPES TO BE SO SITUATED AS TO LET STORMWATER CHANNEL DISCHARGE OVER LOWER PLOT - IN SUCH POSITION AS SUITABLE TO OWNER

SECTION A:A.

ALL 2. CONCRETE SLABS & BEAMS TO ENGINEER'S DETAILS

SCALE: 1:100

REINFORCEMENT:
 $\frac{1}{2}" \phi$ bars at 9" cc in both directions.

K. G. Campbell
18.572.

PART WEST ELEVATION.

ALL TRUJES 0.75" max C.C.

SCALE: 1:50

DRAINAGE SECTION

NOS. OF INSPECTION CHAMBERS	1	2	3	4
FALL OF DRAIN	1:40	✓ STEEP.	1:40	✓
KIND OF PIPE	10cm ϕ CAST IRON PIPE			✓
GROUND LEVELS	UNDER FLOOR = 100.00 m	Independent of the WMC and in concrete. 101.15 m	99.80	97.30 97.30
INVERT LEVELS	- 40cm = 99.60 m	99.12 m	98.94	96.80 96.90
DISTANCES BETWEEN CHAMBERS	18.20 m	7.00 m	5.00 m	1.70 m

SCALE: 1:100.

K. J. Ansfield
25.4.72,